



1-Placement of equipment is dependant on the size of the communication room. Modifications will be provided at the time confirmation of room size is received by UIT.

2- Sprinkler heads, water pipes or drains should NOT be placed over network cabinets

3-All rooms will have a door lock with a number 3 key.

REVISION:		
1	July 18, 2018	MD
2		
3		
4		
5		

PROJECT NAME:
UIT – Infrastructure Planning Standards

DRAWING NAME:
Comm Room Shell-Build Out

DRAWN BY: TW

APPROVED BY: MD

DATE: July 18, 2018

SCALE: NTS

PROJECT #:

ISSUE #: 2

DRAWING #:
UIT-ICT-03